



Certificate no.:
TAE000050B

TYPE APPROVAL CERTIFICATE

This is to certify:

that the **Electric Power Cable**

with type designation(s)

CJPF86/SC, CJPF96/SC, CJPJ85/SC, CJPJ95/SC

issued to

Anhui Tiankang (Group) Shares Co., Ltd.
Tianchang, China

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Rated voltage (kV) 0,6/1

Temp. class (°C) 90

Issued at **Hamburg** on **2025-01-07**

This Certificate is valid until **2030-01-06**.

DNV local unit: **Nanjing NB & CMC**

Approval Engineer: **Carsten Hunsalz**

for **DNV**
Digitally signed
by Elter,
Frederik Tore
Location: DNV
Høvik, Norway



This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

XLPE insulated shipboard power cables

Type CJPJ86/SC, CJPJ96/SC, CJPJ85/SC, CJPJ95/SC

Construction:

Conductor: Tinned stranded copper, class 2

Insulation: XLPE

Inner sheath: PF - SHF1

PJ - SHF2

Armour / braid: 8 - Copper wire braid

9 - Galvanized steel wire braid (not for single core cable)

Outer sheath: 5 - SHF2

6 - SHF1

Number of cores x cross section mm ²	Overall Diameter [mm] nom.
1×1,0	7,3
1×1,5	7,6
1×2,5	8,0
1×4	8,6
1×6	9,1
1×10	10,1
1×16	11,1
1×25	13,2
1×35	14,5
1×50	16,0
1×70	18,2
1×95	20,1
1×120	22,7
1×150	24,6
1×185	26,6
2×1,0	10,5
2×1,5	11,1
2×2,5	12,2
2×4	13,4
2×6	15,0
2×10	17,2
2×16	19,6
2×25	23,4
2×35	25,8
2×50	28,2
2×70	32,2
2×95	37,1
2×120	42,7
2×150	47,5
2×185	51,7

Number of cores x cross section mm ²	Overall Diameter [mm] nom.
3×1,0	10,9
3×1,5	11,6
3×2,5	12,9
3×4	14,5
3×6	16,0
3×10	18,3
3×16	20,6
3×25	24,7
3×35	27,4
3×50	30,2
3×70	34,5
3×95	39,5
3×120	44,8
3×150	48,9
3×185	53,4
4×1,0	11,6
5×1,0	12,8
7×1,0	13,6
8×1,0	14,9
10×1,0	17,0
12×1,0	17,6
14×1,0	18,3
16×1,0	19,3
19×1,0	20,1
24×1,0	23,2
27×1,0	23,6
30×1,0	24,3
37×1,0	26,3
4×1,5	12,8
5×1,5	14,0

Number of cores x cross section mm ²	Overall Diameter [mm] nom.
7×1,5	15,0
8×1,5	16,0
10×1,5	18,4
12×1,5	19,1
14×1,5	19,8
16×1,5	20,7
19×1,5	22,0
24×1,5	25,2
27×1,5	25,7
30×1,5	26,6
37×1,5	28,6
4×2,5	13,8
5×2,5	15,3
7×2,5	16,5
8×2,5	17,8
10×2,5	20,4
12×2,5	20,9
14×2,5	22,2
16×2,5	23,2
19×2,5	24,2
24×2,5	28,2
27×2,5	28,8
30×2,5	29,7
37×2,5	32,1

Application/Limitation

General power and lighting. Control.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

Flame retardant Cat. A. Halogen free. Low smoke.

Type Approval documentation

Test report: TN24-4513E, TN24-4511E, TN24-4512E, TN24-4510E,

Specification: Anhui Tiangkang (Group) Shares Co., Ltd. updated for DNV 2024

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2020-01	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2024-06	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2019-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Clause 45.2 Methods of determination of low levels of fluorine	Fluorine content < 0,1%
IEC 61034-1/2	2019-11	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

Example:

Anhui Tiangkang (Group) Shares Co., Ltd. - CJPJ85/SC - 0,6/1kV - size - IEC 60332-3-22 - Lot no.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE